



SCHEDULE

ITEM	QTY	MODEL						OPENING SIZE		NON-STANDARD VIEWPORT LOCATION **(SEE NOTE 5) 'H' (WHEN REQ'D)	NON-STANDARD INSULATION			IDENTIFICATION
		HH	10	15	20	**VIEWPORT L/H	**VIEWPORT R/H	*'A' WIDTH	*'B' HEIGHT		1 1/2 LB	3 LB	8 LB	
		HH												
		HH												
		HH												
		HH												
		HH												
		HH												

NOTES

- HINGE ALWAYS FURNISHED ON 'B' HEIGHT DIMENSION.
- (G) DESIGNATES DOORS WITH GLASS VIEWPORTS, SPECIFY (L/H) LEFT HAND OR (R/H) RIGHT HAND HINGE WHEN VIEWING FROM THE OUTSIDE.
- 9" x 9" GLASS VIEWPORT NOT AVAILABLE ON UNITS UNDER 18" IN WIDTH AND 12" x 12" VIEWPORTS NOT AVAILABLE ON UNITS UNDER 21" IN WIDTH.
- *4. UNLESS OTHERWISE SPECIFIED, DOOR WILL BE FABRICATED 1/4" UNDER LISTED SIZE. DIMENSIONAL TOLERANCE IS ±.075.
- **5. UNLESS OTHERWISE SPECIFIED, STANDARD VIEWPORT LOCATIONS ARE AS FOLLOWS:
'H'='B'-11" (±1") WHEN 'B' IS 20" TO 60"
'H'=48" (±1") WHEN 'B' IS GREATER THAN 60"
WHEN SPECIFYING NON-STANDARD VIEWPORT LOCATIONS, 'H' CANNOT BE GREATER THAN 'B'-11"
- MINIMUM SIZE 12" WIDE x 12" HIGH
MAXIMUM SIZE 48" WIDE x 96" HIGH
(WIDTH CANNOT EXCEED 2x HEIGHT)
- OPTIONAL MATERIALS AVAILABLE FOR THE FOLLOWING COMPONENTS:
DOOR PANELS-BONDERIZED STEEL,
OR STAINLESS STEEL
VIEWPORT GLASS-SINGLE PANE: 1/4" PLEXIGLASS
DOUBLE PANE: 1/4" WIRE
1/4" WIRE THERMAL PANE
HANDLES-CHROME PLATED
- PLEASE REFER TO INSTALLATION INSTRUCTIONS FOR MOUNTING OF HANDLES, AND DOOR ASSEMBLY MOUNTING.

SPECIFICATIONS

FLANGED FRAME
16 GA GALV. STEEL

INSULATION
FIBERGLASS 3/4 LB DENSITY

HINGE
STAINLESS STEEL CONTINUOUS TYPE

DOOR PANELS
20 GA GALV. STEEL

HANDLES
DUAL ACTING
DIE CAST ZINC

VIEWPORT GLASS (SINGLE PANE)
1/4" WIRE
(9"x9" STANDARD)
(12"x12" OPTIONAL)

CHANNEL SUPPORT
16 GA GALV. STEEL

GASKET
CONTINUOUS LENGTH
REPLACEABLE NEOPRENE BULB

FINISH
MILL

PROJECT/LOCATION

ARCHITECT/ENGINEER

CONTRACTOR

SALES ENGINEER

LD LOUVERS & DAMPERS
A MESTEK COMPANY

7435 INDUSTRIAL RD Phone: (859) 538-3450
FLORENCE, KY Fax: (859) 647-7810

FABRICATED ACCESS DOOR-MODELS HH10,15,20

DRAWN BY
LCC
DATE
4/26/02

DRAWING NO.
F158-320